

A REPORT ON THE APPLICATION OF
THE ESIL TECHNOLOGY TO
THE TREATMENT OF
E-COLI

DECEMBER 18, 1995



walker laboratories

division of Niagara Waste Systems Limited

P O BOX 100, THOROLD, ONTARIO, L2V 3Y8
LOCATION: THOROLD TOWNSHIP, NIAGARA FALLS

TEL: (905) 227-1115
FAX: (905) 660-1127
BUFFALO, N.Y.
TEL: (716) 634-0011
NIAGARA FALLS, N.Y.
TEL: (716) 285-3669

Order # 95-12-095
12/18/95

Page 2

TEST RESULTS BY SAMPLE

| | | | | |
|------------------------------|---------------------|------------------------|-----------------------|-------------|
| Sample: 01A Raw Effluent | Collected: 12/13/95 | | | |
| <u>Test Description</u> | <u>Results</u> | <u>Detection Limit</u> | <u>Units Analyzed</u> | <u>By</u> |
| E. Coli | 3200000 | | counts/100ml | 12/15/95 MD |
| | | | | |
| Sample: 02A Treated Effluent | Collected: 12/13/95 | | | |
| <u>Test Description</u> | <u>Results</u> | <u>Detection Limit</u> | <u>Units Analyzed</u> | <u>By</u> |
| E Coli | 120 | | counts/100ml | 12/15/95 MD |
| | | | | |
| Sample: 03A Filtrate | Collected: 12/13/95 | | | |
| <u>Test Description</u> | <u>Results</u> | <u>Detection Limit</u> | <u>Units Analyzed</u> | <u>By</u> |
| E Coli | < 2 | | counts/100ml | 12/15/95 MD |

The information in this document may contain legally privileged and/or confidential information. If the receiver of this document or fax transmission is not the intended recipient, he is hereby notified that the distribution or reproduction to anyone other than the addressee is strictly prohibited.

A MEMBER OF IAETL CANADA
ACCREDITED BY CAEAL FOR SPECIFIC TESTS REGISTERED WITH THE ASSOCIATION